

Facility Inventory *RAY ST* LOCATION: *MEMORIAL ATHLETIC FOOTBALL & BASEBALL FIELD*

ACTIVITY	EQUIPMENT	NOTES	
Picnic Facilities	Tables & Benches	Located adjacent to accessible paths	
		Access to Open Spaces	
	Grills	Back and Arm Rests	
		Adequate number	
	Trash Cans	Height of Cooking Surface	
Picnic Shelters	Located adjacent to accessible paths		
	Located near accessible water fountains, trash can, restroom, parking, etc.		
Trails		Located adjacent to accessible paths	
		Surface material	
		Dimensions	
		Rails	
Swimming Facilities	Pools	Signage (for visually impaired)	
		Entrance	
		Location from accessible parking	
	Beaches	Safety features i.e. warning for visually impaired	
		Location from accessible path into water	
		Handrails	
Play Areas (tot lots)	All Play Equipment i.e. swings, slides	Location from accessible parking	
	Access Routes	Shade provided	
		Same experience provided to all	
<u>Game Areas:</u> *ballfield *basketball *tennis	Access Routes	Located adjacent to accessible paths	
	Equipment	Enough space between equipment for wheelchair	
		Access Routes	Located adjacent to accessible paths ✓
		Berm cuts onto courts	
Boat Docks	Access Routes	Height	
		Dimensions	
Fishing Facilities	Access Routes	Spectator Seating ✓ <i>BOTH ACCESSIBLE FOOTBALL & BASEBALL SEATING</i>	
		Located adjacent to accessible paths	
	Equipment	Handrails	
		Arm Rests	
		Bait Shelves	
Programming	Are special programs at your facilities accessible?	Handrails	
		Fish Cleaning Tables	
		Learn-to-Swim	
Services and Technical Assistance		Guided Hikes	
		Interpretive Programs	
Services and Technical Assistance		Information available in alternative formats i.e. for visually impaired	
		Process to request interpretive services (i.e. sign language interpreter) for meetings	

BOTH ACCESSIBLE FOOTBALL & BASEBALL SEATING

LOCATION

PARKING			
<i>Total Spaces</i>	<i>Required Accessible Spaces</i>		
Up to 25	1 space		
26-50	2 spaces ✓ FOOTBALL & BASEBALL FIELDS		
51-75	3 spaces		
76-100	4 spaces (Should have several more)		
101-150	5 spaces		
151-200	6 spaces		
201-300	7 spaces		
301-400	8 spaces		
401-500	9 spaces		
<i>Specification for Accessible Spaces</i>	<i>Yes</i>	<i>No</i>	<i>Comments/Transition Notes</i>
Accessible space located closest to accessible entrance			
Where spaces cannot be located within 200 ft of accessible entrance, drop-off area is provided within 100 ft.			
Minimum width of 13 ft includes 8 ft space plus 5 ft access aisle			
Van space - minimum of 1 van space for every accessible space, 8 ft wide plus 8 ft aisle. Alternative is to make all accessible spaces 11 ft wide with 5 ft aisle.			
Sign with international symbol of accessibility at each space or pair of spaces			
Sign minimum 5 ft, maximum 8 ft to top of sign			
Surface evenly paved or hard-packed (no cracks)			
Surface slope less than 1:20, 5%			
Curbcut to pathway from parking lot at each space or pair of spaces, if sidewalk (curb) is present			
Curbcut is a minimum width of 3 ft, excluding sloped sides, has sloped sides, all slopes not to exceed 1:12, and textured or painted yellow			
RAMPS			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/Transition Notes</i>
Slope Maximum 1:12	✓		RAMPS w/HAND RAILINGS ON EACH SPECTATOR SEATING FOR FOOTBALL & BASEBALL
Minimum width 4 ft between handrails			
Handrails on both sides if ramp is longer than 6 ft			
Handrails at 34" and 19" from ramp surface			
Handrails extend 12" beyond top and bottom			
Handgrip oval or round			
Handgrip smooth surface			
Handgrip diameter between 1½" and 2"			
Clearance of 1½" between wall and wall rail			
Non-slip surface			
Level platforms (4ft x 4 ft) at every 30 ft, at top, at bottom, at change of direction			

LOCATION

SITE ACCESS, PATH OF TRAVEL, ENTRANCES			
Specification	Yes	No	Comments/Transition Notes
Site Access			
Accessible path of travel from passenger disembarking area and parking area to accessible entrance	✓		
Disembarking area at accessible entrance	✓		
Surface evenly paved or hard-packed	✓		
No ponding of water	✓		
Path of Travel			
Path does not require the use of stairs		✓	
Path is stable, firm and slip resistant		✓	
3 ft wide minimum		✓	
Slope maximum 1:20 (5%) and maximum cross pitch is 2% (1:50).	✓		
Continuous common surface, no changes in level greater than 1/4 inch	✓		
Any objects protruding onto the pathway must be detected by a person with a visual disability using a cane		NONE	
Objects protruding more than 4" from the wall must be within 27" of the ground, or higher than 80"			
Curb on the pathway must have curb cuts at drives, parking and drop-offs			
Entrances			
Primary public entrances accessible to person using wheelchair, must be signed, gotten to independently, and <i>not</i> be the service entrance		✓	
Level space extending 5 ft. from the door, interior and exterior of entrance doors			BOTH THESE FACILITIES ARE OUTDOOR ATHLETIC SPORT FIELDS
Minimum 32" clear width opening (i.e. 36" door with standard hinge)			
At least 18" clear floor area on latch, pull side of door			
Door handle no higher than 48" and operable with a closed fist			
Vestibule is 4 ft plus the width of the door swinging into the space			
Entrance(s) on a level that makes elevators accessible			
Door mats less than 1/2" thick are securely fastened			
Door mats more than 1/2" thick are recessed			
Grates in path of travel have openings of 1/2" maximum			
Signs at non-accessible entrance(s) indicate direction to accessible entrance		✓	
Emergency egress - alarms with flashing lights and audible signals, sufficiently lighted		✓	

NOTES

LOCATION

STAIRS and DOORS			
Specification	Yes	No	Comments/Transition Notes
<i>Stairs</i> <i>NONE</i>			
No open risers			
Nosings not projecting			
Treads no less than 11" wide			
Handrails on both sides			
Handrails 34"-38" above tread			
Handrail extends a minimum of 1 ft beyond top and bottom riser (if no safety hazard and space permits)			
Handgrip oval or round			
Handgrip has a smooth surface			
Handgrip diameter between 1¼" and 1½"			
1½" clearance between wall and handrail			
<i>Doors</i> <i>NONE</i>			
Minimum 32" clear opening			
At least 18" clear floor space on pull side of door			
Closing speed minimum 3 seconds to within 3" of the latch			
Maximum pressure 5 pounds interior doors			
Threshold maximum ½" high, beveled on both sides			
Hardware operable with a closed fist (no conventional door knobs or thumb latch devices)			
Hardware minimum 36", maximum 48" above the floor			
Clear, level floor space extends out 5 ft from both sides of the door			
Door adjacent to revolving door is accessible and unlocked			
Doors opening into hazardous area have hardware that is knurled or roughened			

NOTES

DOORS & WALK WAYS TO BATHROOM FACILITIES ARE HANDICAP ACCESSED.

LOCATION

RESTROOMS - also see Doors and Vestibules			
Specification	Yes	No	Comments/Transition Notes
5 ft turning space measured 12" from the floor			
<i>At least one Sink:</i>			
Clear floor space of 30" by 48" to allow a forward approach			
Mounted without pedestal or legs, height 34" to top of rim			
Extends at least 22" from the wall			
Open knee space a minimum 19" deep, 30" width, and 27" high			
Cover exposed pipes with insulation			
Faucets operable with closed fist (lever or spring activated handle)			
<i>At least one Stall:</i>			
Accessible to person using wheelchair at 60" wide by 72" deep			
Stall door is 36" wide			
Stall door swings out			
Stall door is self closing			
Stall door has a pull latch			
Lock on stall door is operable with a closed fist, and 32" above the floor			
Coat hook is 54" high			
<i>Toilet</i>			
18" from center to nearest side wall			
42" minimum clear space from center to farthest wall or fixture			
Top of seat 17"-19" above the floor			
<i>Grab Bars</i>			
On back and side wall closest to toilet			
1½" diameter			
1½" clearance to wall			
Located 30" above and parallel to the floor			
Acid-etched or roughened surface			
42" long			
<i>Fixtures</i>			
Toilet paper dispenser is 24" above floor			
One mirror set a maximum 38" to bottom (if tilted, 42")			
Dispensers (towel, soap, etc) at least one of each a maximum 42" above the floor			

NOTES ACCESS COMPLETELY REMODELED TO MEET FEDERAL GUIDELINES
BATHROOMS

LOCATION

FLOORS, DRINKING FOUNTAINS, TELEPHONES			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/Transition Notes</i>
Floors			
Non-slip surface			
Carpeting is high-density, low pile, non-absorbent, stretched taut, securely anchored			NO CARPETS
Corridor width minimum is 3 ft			
Objects (signs, ceiling lights, fixtures) can only protrude 4" into the path of travel from a height of 27" to 80" above the floor			
Drinking Fountains			
Spouts no higher than 36" from floor to outlet			
Hand operated push button or level controls			
Spouts located near front with stream of water as parallel to front as possible			
If recessed, recess a minimum 30" width, and no deeper than depth of fountain			
If no clear knee space underneath, clear floor space 30" x 48" to allow parallel approach			
Telephones			
Highest operating part a maximum 54" above the floor			
Access within 12" of phone, 30" high by 30" wide			
Adjustable volume control on headset so identified			
SIGNS, SIGNALS, AND SWITCHES			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/Transition Notes</i>
Switches, Controls and Signs			
Switches and controls for light, heat, ventilation, windows, fire alarms, thermostats, etc, must be a minimum of 36" and a maximum of 48" above the floor for a forward reach, a maximum of 54" for a side reach			
Electrical outlets centered no lower than 18" above the floor			
Warning signals must be visual as well as audible			
Signs			
Mounting height must be 60" to centerline of the sign			
Within 18" of door jamb or recessed			
Letters and numbers a t least 1¼" high			
Letters and numbers raised .03"			
Letters and numbers contrast with the background color			

NOTES

Facility Inventory

LOCATION: JACK BENNY SOFTBALL FIELDS (OUTDOOR FACILITY)

ACTIVITY	EQUIPMENT	NOTES
Picnic Facilities	Tables & Benches	Located adjacent to accessible paths
		Access to Open Spaces
		Back and Arm Rests
		Adequate number
	Grills	Height of Cooking Surface
	Trash Cans	Located adjacent to accessible paths
Picnic Shelters	Picnic Shelters	Located adjacent to accessible paths
		Located near accessible water fountains, trash can, restroom, parking, etc.
Trails		Surface material
		Dimensions
		Rails
		Signage (for visually impaired)
Swimming Facilities	Pools	Entrance
		Location from accessible parking
		Safety features i.e. warning for visually impaired
	Beaches	Location from accessible path into water
		Handrails
		Location from accessible parking
Play Areas (tot lots)	All Play Equipment i.e. swings, slides	Same experience provided to all
	Access Routes	Located adjacent to accessible paths
		Enough space between equipment for wheelchair
JACK BENNY Game Areas: *ballfield *basketball *tennis SOFTBALL	Access Routes	Located adjacent to accessible paths ✓
		Berm cuts onto courts
	Equipment	Height
		Dimensions
		Spectator Seating
	Boat Docks	Access Routes
Handrails		
Fishing Facilities	Access Routes	Located adjacent to accessible paths
		Handrails
	Equipment	Arm Rests
		Bait Shelves
		Fish Cleaning Tables
Programming	Are special programs at your facilities accessible?	Learn-to-Swim
		Guided Hikes
		Interpretive Programs
Services and Technical Assistance		Information available in alternative formats i.e. for visually impaired
		Process to request interpretive services (i.e. sign language interpreter) for meetings

LOCATION

PARKING			
<i>Total Spaces</i>	<i>Required Accessible Spaces</i>		
Up to 25	1 space		
26-50	2 spaces ✓		
51-75	3 spaces		
76-100	4 spaces		
101-150	5 spaces		
151-200	6 spaces		
201-300	7 spaces		
301-400	8 spaces		
401-500	9 spaces		
<i>Specification for Accessible Spaces</i>	<i>Yes</i>	<i>No</i>	<i>Comments/Transition Notes</i>
Accessible space located closest to accessible entrance	✓		
Where spaces cannot be located within 200 ft of accessible entrance, drop-off area is provided within 100 ft.			
Minimum width of 13 ft includes 8 ft space plus 5 ft access aisle	✓		
Van space - minimum of 1 van space for every accessible space, 8 ft wide plus 8 ft aisle. Alternative is to make all accessible spaces 11 ft wide with 5 ft aisle.	✓		
Sign with international symbol of accessibility at each space or pair of spaces	✓		
Sign minimum 5 ft, maximum 8 ft to top of sign			
Surface evenly paved or hard-packed (no cracks)			
Surface slope less than 1:20, 5%	✓		
Curbscut to pathway from parking lot at each space or pair of spaces, if sidewalk (curb) is present			
Curbscut is a minimum width of 3 ft, excluding sloped sides, has sloped sides, all slopes not to exceed 1:12, and textured or painted yellow			
RAMPS - NONE - NOT NEEDED			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/Transition Notes</i>
Slope Maximum 1:12			
Minimum width 4 ft between handrails			
Handrails on both sides if ramp is longer than 6 ft			
Handrails at 34" and 19" from ramp surface			
Handrails extend 12" beyond top and bottom			
Handgrip oval or round			
Handgrip smooth surface			
Handgrip diameter between 1½" and 2"			
Clearance of 1½" between wall and wall rail			
Non-slip surface			
Level platforms (4ft x 4 ft) at every 30 ft, at top, at bottom, at change of direction			

LOCATION

SITE ACCESS, PATH OF TRAVEL, ENTRANCES			
Specification	Yes	No	Comments/Transition Notes
Site Access			
Accessible path of travel from passenger disembarking area and parking area to accessible entrance	✓		
Disembarking area at accessible entrance	✓		
Surface evenly paved or hard-packed	✓		
No ponding of water	✓		
Path of Travel			
Path does not require the use of stairs		✓	
Path is stable, firm and slip resistant	✓		
3 ft wide minimum	✓		
Slope maximum 1:20 (5%) and maximum cross pitch is 2% (1:50).	✓		
Continuous common surface, no changes in level greater than 1/4 inch			
Any objects protruding onto the pathway must be detected by a person with a visual disability using a cane			
Objects protruding more than 4" from the wall must be within 27" of the ground, or higher than 80"			
Curb on the pathway must have curb cuts at drives, parking and drop-offs			
ENTRANCES <i>OUT DOOR LOCATION</i>			
Primary public entrances accessible to person using wheelchair, must be signed, gotten to independently, and <i>not</i> be the service entrance			
Level space extending 5 ft. from the door, interior and exterior of entrance doors			
Minimum 32" clear width opening (i.e. 36" door with standard hinge)			
At least 18" clear floor area on latch, pull side of door			
Door handle no higher than 48" and operable with a closed fist			
Vestibule is 4 ft plus the width of the door swinging into the space			
Entrance(s) on a level that makes elevators accessible			
Door mats less than 1/2" thick are securely fastened			
Door mats more than 1/2" thick are recessed			
Grates in path of travel have openings of 1/2" maximum			
Signs at non-accessible entrance(s) indicate direction to accessible entrance			
Emergency egress - alarms with flashing lights and audible signals, sufficiently lighted			

NOTES

LOCATION

STAIRS and DOORS			
<i>NO STAIRS OR DOORS</i>			
Specification	Yes	No	Comments/Transition Notes
<i>Stairs</i>			
No open risers			
Nosings not projecting			
Treads no less than 11" wide			
Handrails on both sides			
Handrails 34"-38" above tread			
Handrail extends a minimum of 1 ft beyond top and bottom riser (if no safety hazard and space permits)			
Handgrip oval or round			
Handgrip has a smooth surface			
Handgrip diameter between 1¼" and 1½"			
1½" clearance between wall and handrail			
<i>Doors</i>			
Minimum 32" clear opening			
At least 18" clear floor space on pull side of door			
Closing speed minimum 3 seconds to within 3" of the latch			
Maximum pressure 5 pounds interior doors			
Threshold maximum ½" high, beveled on both sides			
Hardware operable with a closed fist (no conventional door knobs or thumb latch devices)			
Hardware minimum 36", maximum 48" above the floor			
Clear, level floor space extends out 5 ft from both sides of the door			
Door adjacent to revolving door is accessible and unlocked			
Doors opening into hazardous area have hardware that is knurled or roughened			

NOTES

LOCATION

RESTROOMS - also see Doors and Vestibules			
Specification	Yes	No	Comments/Transition Notes
5 ft turning space measured 12" from the floor	✓		
<i>At least one Sink:</i> MEETS FEDERAL SPEC'S			
Clear floor space of 30" by 48" to allow a forward approach			
Mounted without pedestal or legs, height 34" to top of rim			
Extends at least 22" from the wall			
Open knee space a minimum 19" deep, 30" width, and 27" high			
Cover exposed pipes with insulation			
Faucets operable with closed fist (lever or spring activated handle)			
<i>At least one Stall:</i> MEETS FEDERAL SPEC'S			
Accessible to person using wheelchair at 60" wide by 72" deep			
Stall door is 36" wide			
Stall door swings out			
Stall door is self closing			
Stall door has a pull latch			
Lock on stall door is operable with a closed fist, and 32" above the floor			
Coat hook is 54" high			
<i>Toilet</i> MEETS FEDERAL SPEC'S			
18" from center to nearest side wall			
42" minimum clear space from center to farthest wall or fixture			
Top of seat 17"-19" above the floor			
<i>Grab Bars</i>			
On back and side wall closest to toilet			
1 1/4" diameter			
1 1/2" clearance to wall			
Located 30" above and parallel to the floor			
Acid-etched or roughened surface			
42" long			
<i>Fixtures</i>			
Toilet paper dispenser is 24" above floor			
One mirror set a maximum 38" to bottom (if tilted, 42")			
Dispensers (towel, soap, etc) at least one of each a maximum 42" above the floor			

NOTES

LOCATION

FLOORS, DRINKING FOUNTAINS, TELEPHONES			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/Transition Notes</i>
Floors			
Non-slip surface	✓		
Carpeting is high-density, low pile, non-absorbent, stretched taut, securely anchored			NO CARPETS
Corridor width minimum is 3 ft			
Objects (signs, ceiling lights, fixtures) can only protrude 4" into the path of travel from a height of 27" to 80" above the floor			
Drinking Fountains			
Spouts no higher than 36" from floor to outlet	✓		
Hand operated push button or level controls			
Spouts located near front with stream of water as parallel to front as possible			
If recessed, recess a minimum 30" width, and no deeper than depth of fountain			
If no clear knee space underneath, clear floor space 30" x 48" to allow parallel approach			
Telephones			
Highest operating part a maximum 54" above the floor	✓		
Access within 12" of phone, 30" high by 30" wide			
Adjustable volume control on headset so identified			
SIGNS, SIGNALS, AND SWITCHES			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/Transition Notes</i>
Switches, Controls and Signs			
Switches and controls for light, heat, ventilation, windows, fire alarms, thermostats, etc, must be a minimum of 36" and a maximum of 48" above the floor for a forward reach, a maximum of 54" for a side reach			
Electrical outlets centered no lower than 18" above the floor			
Warning signals must be visual as well as audible			
Signs			
Mounting height must be 60" to centerline of the sign	✓		
Within 18" of door jamb or recessed			
Letters and numbers at least 1½" high			
Letters and numbers raised .03"			
Letters and numbers contrast with the background color			

NOTES

BUILT TO FEDERAL GUIDE LINES

Facility Inventory

LOCATION: MAY ST PLAYGROUND/WALKING PATH

ACTIVITY	EQUIPMENT	NOTES
Picnic Facilities	Tables & Benches	Located adjacent to accessible paths
		Access to Open Spaces
		Back and Arm Rests
		Adequate number
	Grills	Height of Cooking Surface
Trash Cans	Picnic Shelters	Located adjacent to accessible paths
		Located adjacent to accessible paths
		Located adjacent to accessible paths
		Located near accessible water fountains, trash can, restroom, parking, etc.
Trails WALKING		Surface material
		Dimensions
		Rails
		Signage (for visually impaired)
Swimming Facilities	Pools	Entrance
		Location from accessible parking
		Safety features i.e. warning for visually impaired
	Beaches	Location from accessible path into water
		Handrails
Play Areas (tot lots)	All Play Equipment i.e. swings, slides	Same experience provided to all ✓
	Access Routes	Located adjacent to accessible paths ✓
		Enough space between equipment for wheelchair ✓
Game Areas: *ballfield *basketball *tennis	Access Routes	Located adjacent to accessible paths ✓
		Berm cuts onto courts ✓
	Equipment	Height ✓
		Dimensions ✓
		Spectator Seating ✓
Boat Docks	Access Routes	Located adjacent to accessible paths
		Handrails
Fishing Facilities	Access Routes	Located adjacent to accessible paths
		Handrails
	Equipment	Arm Rests
		Bait Shelves
		Handrails
Programming	Are special programs at your facilities accessible?	Fish Cleaning Tables
		Learn-to-Swim
		Guided Hikes
Services and Technical Assistance		Interpretive Programs
		Information available in alternative formats i.e. for visually impaired
		Process to request interpretive services (i.e. sign language interpreter) for meetings

LOCATION

MAY ST - BUILT TO MEET FEDERAL GUIDELINES

PARKING			
Total Spaces	Required Accessible Spaces		
Up to 25	1 space		
26-50	2 spaces		
51-75	3 spaces		
76-100	4 spaces		
101-150	5 spaces		
151-200	6 spaces		
201-300	7 spaces		
301-400	8 spaces		
401-500	9 spaces		
Specification for Accessible Spaces	Yes	No	Comments/Transition Notes
Accessible space located closest to accessible entrance			
Where spaces cannot be located within 200 ft of accessible entrance, drop-off area is provided within 100 ft.			
Minimum width of 13 ft includes 8 ft space plus 5 ft access aisle			
Van space - minimum of 1 van space for every accessible space, 8 ft wide plus 8 ft aisle. Alternative is to make all accessible spaces 11 ft wide with 5 ft aisle.			
Sign with international symbol of accessibility at each space or pair of spaces			
Sign minimum 5 ft, maximum 8 ft to top of sign			
Surface evenly paved or hard-packed (no cracks)			
Surface slope less than 1:20, 5%			
Curbcut to pathway from parking lot at each space or pair of spaces, if sidewalk (curb) is present			
Curbcut is a minimum width of 3 ft, excluding sloped sides, has sloped sides, all slopes not to exceed 1:12, and textured or painted yellow			
RAMPS			
Specification	Yes	No	Comments/Transition Notes
Slope Maximum 1:12			
Minimum width 4 ft between handrails			
Handrails on both sides if ramp is longer than 6 ft			
Handrails at 34" and 19" from ramp surface			
Handrails extend 12" beyond top and bottom			
Handgrip oval or round			
Handgrip smooth surface			
Handgrip diameter between 1½" and 2"			
Clearance of 1½" between wall and wall rail			
Non-slip surface			
Level platforms (4ft x 4 ft) at every 30 ft, at top, at bottom, at change of direction			

LOCATION

SITE ACCESS, PATH OF TRAVEL, ENTRANCES			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/Transition Notes</i>
Site Access			
Accessible path of travel from passenger disembarking area and parking area to accessible entrance			
Disembarking area at accessible entrance			
Surface evenly paved or hard-packed			
No ponding of water			
Path of Travel			
Path does not require the use of stairs			
Path is stable, firm and slip resistant			
3 ft wide minimum			
Slope maximum 1:20 (5%) and maximum cross pitch is 2% (1:50).			
Continuous common surface, no changes in level greater than $\frac{1}{2}$ inch			
Any objects protruding onto the pathway must be detected by a person with a visual disability using a cane			
Objects protruding more than 4" from the wall must be within 27" of the ground, or higher than 80"			
Curb on the pathway must have curb cuts at drives, parking and drop-offs			
Entrances			
Primary public entrances accessible to person using wheelchair, must be signed, gotten to independently, and <i>not</i> be the service entrance			
Level space extending 5 ft. from the door, interior and exterior of entrance doors			
Minimum 32" clear width opening (i.e. 36" door with standard hinge)			
At least 18" clear floor area on latch, pull side of door			
Door handle no higher than 48" and operable with a closed fist			
Vestibule is 4 ft plus the width of the door swinging into the space			
Entrance(s) on a level that makes elevators accessible			
Door mats less than $\frac{1}{2}$ " thick are securely fastened			
Door mats more than $\frac{1}{2}$ " thick are recessed			
Grates in path of travel have openings of $\frac{1}{2}$ " maximum			
Signs at non-accessible entrance(s) indicate direction to accessible entrance			
Emergency egress - alarms with flashing lights and audible signals, sufficiently lighted			

NOTES

LOCATION

STAIRS and DOORS			
Specification	Yes	No	Comments/Transition Notes
Stairs			
No open risers			
Nosings not projecting			
Treads no less than 11" wide			
Handrails on both sides			
Handrails 34"-38" above tread			
Handrail extends a minimum of 1 ft beyond top and bottom riser (if no safety hazard and space permits)			
Handgrip oval or round			
Handgrip has a smooth surface			
Handgrip diameter between 1¼" and 1½"			
1½" clearance between wall and handrail			
Doors			
Minimum 32" clear opening			
At least 18" clear floor space on pull side of door			
Closing speed minimum 3 seconds to within 3" of the latch			
Maximum pressure 5 pounds interior doors			
Threshold maximum ½" high, beveled on both sides			
Hardware operable with a closed fist (no conventional door knobs or thumb latch devices)			
Hardware minimum 36", maximum 48" above the floor			
Clear, level floor space extends out 5 ft from both sides of the door			
Door adjacent to revolving door is accessible and unlocked			
Doors opening into hazardous area have hardware that is knurled or roughened			

NOTES

LOCATION

RESTROOMS - also see Doors and Vestibules			
Specification	Yes	No	Comments/Transition Notes
5 ft turning space measured 12" from the floor			
<i>At least one Sink:</i>			
<u>NO</u> REST ROOMS			
Clear floor space of 30" by 48" to allow a forward approach			
Mounted without pedestal or legs, height 34" to top of rim			
Extends at least 22" from the wall			
Open knee space a minimum 19" deep, 30" width, and 27" high			
Cover exposed pipes with insulation			
Faucets operable with closed fist (lever or spring activated handle)			
<i>At least one Stall:</i>			
Accessible to person using wheelchair at 60" wide by 72" deep			
Stall door is 36" wide			
Stall door swings out			
Stall door is self closing			
Stall door has a pull latch			
Lock on stall door is operable with a closed fist, and 32" above the floor			
Coat hook is 54" high			
<i>Toilet</i>			
18" from center to nearest side wall			
42" minimum clear space from center to farthest wall or fixture			
Top of seat 17"-19" above the floor			
<i>Grab Bars</i>			
On back and side wall closest to toilet			
1½" diameter			
1½" clearance to wall			
Located 30" above and parallel to the floor			
Acid-etched or roughened surface			
42" long			
<i>Fixtures</i>			
Toilet paper dispenser is 24" above floor			
One mirror set a maximum 38" to bottom (if tilted, 42")			
Dispensers (towel, soap, etc) at least one of each a maximum 42" above the floor			

NOTES

LOCATION

FLOORS, DRINKING FOUNTAINS, TELEPHONES			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/Transition Notes</i>
Floors			
Non-slip surface			
Carpeting is high-density, low pile, non-absorbent, stretched taut, securely anchored			
Corridor width minimum is 3 ft			
Objects (signs, ceiling lights, fixtures) can only protrude 4" into the path of travel from a height of 27" to 80" above the floor			
Drinking Fountains			
Spouts no higher than 36" from floor to outlet			
Hand operated push button or level controls			
Spouts located near front with stream of water as parallel to front as possible			
If recessed, recess a minimum 30" width, and no deeper than depth of fountain			
If no clear knee space underneath, clear floor space 30" x 48" to allow parallel approach			
Telephones			
Highest operating part a maximum 54" above the floor			
Access within 12" of phone, 30" high by 30" wide			
Adjustable volume control on headset so identified			
SIGNS, SIGNALS, AND SWITCHES			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/Transition Notes</i>
Switches, Controls and Signs			
Switches and controls for light, heat, ventilation, windows, fire alarms, thermostats, etc, must be a minimum of 36" and a maximum of 48" above the floor for a forward reach, a maximum of 54" for a side reach			
Electrical outlets centered no lower than 18" above the floor			
Warning signals must be visual as well as audible			
Signs			
Mounting height must be 60" to centerline of the sign			
Within 18" of door jamb or recessed			
Letters and numbers at least 1½" high			
Letters and numbers raised .03"			
Letters and numbers contrast with the background color			

NOTES

Facility Inventory

LOCATION: SLATER STREET FIELDS

ACTIVITY	EQUIPMENT	NOTES
Picnic Facilities	Tables & Benches	Located adjacent to accessible paths
		Access to Open Spaces
		Back and Arm Rests
		Adequate number
	Grills	Height of Cooking Surface
	Trash Cans	Located adjacent to accessible paths
		Located adjacent to accessible paths
Picnic Shelters	Located adjacent to accessible paths	
	Located near accessible water fountains, trash can, restroom, parking, etc.	
Trails		Surface material
		Dimensions
		Rails
		Signage (for visually impaired)
Swimming Facilities	Pools	Entrance
		Location from accessible parking
		Safety features i.e. warning for visually impaired
	Beaches	Location from accessible path into water
		Handrails
		Shade provided
Play Areas (tot lots)	All Play Equipment i.e. swings, slides	Same experience provided to all
	Access Routes	Located adjacent to accessible paths Enough space between equipment for wheelchair
Game Areas: *ballfield *basketball *tennis SOFTBALL	Access Routes	Located adjacent to accessible paths ✓
		Berm cuts onto courts
	Equipment	Height
		Spectator Seating ✓
Boat Docks	Access Routes	Located adjacent to accessible paths
		Handrails
Fishing Facilities	Access Routes	Located adjacent to accessible paths
		Handrails
	Equipment	Arm Rests
		Bait Shelves
		Fish Cleaning Tables
Programming	Are special programs at your facilities accessible?	Learn-to-Swim
		Guided Hikes
		Interpretive Programs
Services and Technical Assistance	Information available in alternative formats i.e. for visually impaired	
	Process to request interpretive services (i.e. sign language interpreter) for meetings	

LOCATION

PARKING			
<i>Total Spaces</i>	<i>Required Accessible Spaces</i>		
Up to 25	1 space ✓		
26-50	2 spaces		
51-75	3 spaces		
76-100	4 spaces		
101-150	5 spaces		
151-200	6 spaces		
201-300	7 spaces		
301-400	8 spaces		
401-500	9 spaces		
<i>Specification for Accessible Spaces</i>	<i>Yes</i>	<i>No</i>	<i>Comments/Transition Notes</i>
Accessible space located closest to accessible entrance	✓		
Where spaces cannot be located within 200 ft of accessible entrance, drop-off area is provided within 100 ft.			
Minimum width of 13 ft includes 8 ft space plus 5 ft access aisle			
Van space - minimum of 1 van space for every accessible space, 8 ft wide plus 8 ft aisle. Alternative is to make all accessible spaces 11 ft wide with 5 ft aisle.	✓		
Sign with international symbol of accessibility at each space or pair of spaces	✓		
Sign minimum 5 ft, maximum 8 ft to top of sign	✓		
Surface evenly paved or hard-packed (no cracks)	✓		
Surface slope less than 1:20, 5%	✓		
Curbcut to pathway from parking lot at each space or pair of spaces, if sidewalk (curb) is present	✓		
Curbcut is a minimum width of 3 ft, excluding sloped sides, has sloped sides, all slopes not to exceed 1:12, and textured or painted yellow	✓		
NO RAMPS			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/Transition Notes</i>
Slope Maximum 1:12			
Minimum width 4 ft between handrails			
Handrails on both sides if ramp is longer than 6 ft			
Handrails at 34" and 19" from ramp surface			
Handrails extend 12" beyond top and bottom			
Handgrip oval or round			
Handgrip smooth surface			
Handgrip diameter between 1½" and 2"			
Clearance of 1½" between wall and wall rail			
Non-slip surface			
Level platforms (4ft x 4 ft) at every 30 ft, at top, at bottom, at change of direction			

LOCATION

SITE ACCESS, PATH OF TRAVEL, ENTRANCES			
Specification	Yes	No	Comments/Transition Notes
Site Access			
Accessible path of travel from passenger disembarking area and parking area to accessible entrance	✓		
Disembarking area at accessible entrance	✓		
Surface evenly paved or hard-packed	✓		
No ponding of water	✓		
Path of Travel			
Path does not require the use of stairs		✓	
Path is stable, firm and slip resistant	✓		
3 ft wide minimum	✓		
Slope maximum 1:20 (5%) and maximum cross pitch is 2% (1:50).	✓		
Continuous common surface, no changes in level greater than 1/4 inch	✓		
Any objects protruding onto the pathway must be detected by a person with a visual disability using a cane		✓	
Objects protruding more than 4" from the wall must be within 27" of the ground, or higher than 80"		✓	
Curb on the pathway must have curb cuts at drives, parking and drop-offs	✓		
Entrances			
Primary public entrances accessible to person using wheelchair, must be signed, gotten to independently, and <i>not</i> be the service entrance	✓		
Level space extending 5 ft. from the door, interior and exterior of entrance doors			
Minimum 32" clear width opening (i.e. 36" door with standard hinge)			
At least 18" clear floor area on latch, pull side of door			
Door handle no higher than 48" and operable with a closed fist			
Vestibule is 4 ft plus the width of the door swinging into the space			
Entrance(s) on a level that makes elevators accessible			
Door mats less than 1/2" thick are securely fastened			
Door mats more than 1/2" thick are recessed			
Grates in path of travel have openings of 1/2" maximum			
Signs at non-accessible entrance(s) indicate direction to accessible entrance			
Emergency egress - alarms with flashing lights and audible signals, sufficiently lighted			

NOTES

LOCATION

STAIRS and DOORS			
Specification	Yes	No	Comments/Transition Notes
<i>Stairs</i> NO STAIRS			
No open risers			
Nosings not projecting			
Treads no less than 11" wide			
Handrails on both sides			
Handrails 34"-38" above tread			
Handrail extends a minimum of 1 ft beyond top and bottom riser (if no safety hazard and space permits)			
Handgrip oval or round			
Handgrip has a smooth surface			
Handgrip diameter between 1 1/4" and 1 1/2"			
1 1/2" clearance between wall and handrail			
<i>Doors</i> NO DOORS			
Minimum 32" clear opening			
At least 18" clear floor space on pull side of door			
Closing speed minimum 3 seconds to within 3" of the latch			
Maximum pressure 5 pounds interior doors			
Threshold maximum 1/2" high, beveled on both sides			
Hardware operable with a closed fist (no conventional door knobs or thumb latch devices)			
Hardware minimum 36", maximum 48" above the floor			
Clear, level floor space extends out 5 ft from both sides of the door			
Door adjacent to revolving door is accessible and unlocked			
Doors opening into hazardous area have hardware that is knurled or roughened			

NOTES

OUTDOOR SOFTBALL FIELD

LOCATION **HANDICAPPED BATHROOMS HERE MEET FEDERAL SPEC'S**

RESTROOMS - also see Doors and Vestibules			
Specification	Yes	No	Comments/Transition Notes
5 ft turning space measured 12" from the floor	✓		
At least one Sink:			
Clear floor space of 30" by 48" to allow a forward approach	✓		
Mounted without pedestal or legs, height 34" to top of rim	✓		
Extends at least 22" from the wall			
Open knee space a minimum 19" deep, 30" width, and 27" high			
Cover exposed pipes with insulation			
Faucets operable with closed fist (lever or spring activated handle)			
At least one Stall:			
Accessible to person using wheelchair at 60" wide by 72" deep	✓		
Stall door is 36" wide			
Stall door swings out			
Stall door is self closing			
Stall door has a pull latch			
Lock on stall door is operable with a closed fist, and 32" above the floor			
Coat hook is 54" high			
Toilet			
18" from center to nearest side wall			
42" minimum clear space from center to farthest wall or fixture			
Top of seat 17"-19" above the floor			
Grab Bars			
On back and side wall closest to toilet			
1½" diameter			
1½" clearance to wall			
Located 30" above and parallel to the floor			
Acid-etched or roughened surface			
42" long			
Fixtures			
Toilet paper dispenser is 24" above floor	✓		
One mirror set a maximum 38" to bottom (if tilted, 42")			
Dispensers (towel, soap, etc) at least one of each a maximum 42" above the floor			

NOTES

LOCATION

FLOORS, DRINKING FOUNTAINS, TELEPHONES			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/Transition Notes</i>
Floors			
Non-slip surface			
Carpeting is high-density, low pile, non-absorbent, stretched taut, securely anchored			
Corridor width minimum is 3 ft			
Objects (signs, ceiling lights, fixtures) can only protrude 4" into the path of travel from a height of 27" to 80" above the floor			
Drinking Fountains			
Spouts no higher than 36" from floor to outlet			
Hand operated push button or level controls			
Spouts located near front with stream of water as parallel to front as possible			
If recessed, recess a minimum 30" width, and no deeper than depth of fountain			
If no clear knee space underneath, clear floor space 30" x 48" to allow parallel approach			
Telephones			
Highest operating part a maximum 54" above the floor			
Access within 12" of phone, 30" high by 30" wide			
Adjustable volume control on headset so identified			
SIGNS, SIGNALS, AND SWITCHES			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/Transition Notes</i>
Switches, Controls and Signs			
Switches and controls for light, heat, ventilation, windows, fire alarms, thermostats, etc, must be a minimum of 36" and a maximum of 48" above the floor for a forward reach, a maximum of 54" for a side reach			
Electrical outlets centered no lower than 18" above the floor			
Warning signals must be visual as well as audible			
Signs			
Mounting height must be 60" to centerline of the sign			
Within 18" of door jamb or recessed			
Letters and numbers at least 1½" high			
Letters and numbers raised .03"			
Letters and numbers contrast with the background color			

NOTES

Facility Inventory

LOCATION: GEORGE STREET SOCCER FIELDS

ACTIVITY	EQUIPMENT	NOTES
Picnic Facilities	Tables & Benches	Located adjacent to accessible paths
		Access to Open Spaces
		Back and Arm Rests
		Adequate number
	Grills	Height of Cooking Surface
	Trash Cans	Located adjacent to accessible paths
		Located adjacent to accessible paths
Picnic Shelters	Located adjacent to accessible paths	
	Located near accessible water fountains, trash can, restroom, parking, etc.	
Trails		Surface material
		Dimensions
		Rails
		Signage (for visually impaired)
Swimming Facilities	Pools	Entrance
		Location from accessible parking
		Safety features i.e. warning for visually impaired
	Beaches	Location from accessible path into water
		Handrails
		Location from accessible parking
		Shade provided
Play Areas (tot lots)	All Play Equipment i.e. swings, slides	Same experience provided to all
	Access Routes	Located adjacent to accessible paths
		Enough space between equipment for wheelchair
Game Areas: *ballfield *basketball *tennis	Access Routes	Located adjacent to accessible paths
		Berm cuts onto courts
	Equipment	Height
		Dimensions
		Spectator Seating
Boat Docks	Access Routes	Located adjacent to accessible paths
		Handrails
Fishing Facilities	Access Routes	Located adjacent to accessible paths
		Handrails
	Equipment	Arm Rests
		Bait Shelves
		Handrails
		Fish Cleaning Tables
Programming	Are special programs at your facilities accessible?	Learn-to-Swim
		Guided Hikes
		Interpretive Programs
Services and Technical Assistance	Information available in alternative formats i.e. for visually impaired	
		Process to request interpretive services (i.e. sign language interpreter) for meetings

LOCATION

PARKING			
<i>Total Spaces</i>	<i>Required Accessible Spaces</i>		
Up to 25	1 space ✓		
26-50	2 spaces		
51-75	3 spaces		
76-100	4 spaces		
101-150	5 spaces		
151-200	6 spaces		
201-300	7 spaces		
301-400	8 spaces		
401-500	9 spaces		
<i>Specification for Accessible Spaces</i>	<i>Yes</i>	<i>No</i>	<i>Comments/Transition Notes</i>
Accessible space located closest to accessible entrance			MUST STAY IN MV TO WATCH GAMES. -OR SEE NOTES SUCCEEDING PAGES
Where spaces cannot be located within 200 ft of accessible entrance, drop-off area is provided within 100 ft.			
Minimum width of 13 ft includes 8 ft space plus 5 ft access aisle			
Van space - minimum of 1 van space for every accessible space, 8 ft wide plus 8 ft aisle. Alternative is to make all accessible spaces 11 ft wide with 5 ft aisle.			
Sign with international symbol of accessibility at each space or pair of spaces			
Sign minimum 5 ft, maximum 8 ft to top of sign			
Surface evenly paved or hard-packed (no cracks)			
Surface slope less than 1:20, 5%			
Curbscut to pathway from parking lot at each space or pair of spaces, if sidewalk (curb) is present			
Curbscut is a minimum width of 3 ft, excluding sloped sides, has sloped sides, all slopes not to exceed 1:12, and textured or painted yellow			
RAMPS			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/Transition Notes</i>
Slope Maximum 1:12			
Minimum width 4 ft between handrails			
Handrails on both sides if ramp is longer than 6 ft			
Handrails at 34" and 19" from ramp surface			
Handrails extend 12" beyond top and bottom			
Handgrip oval or round			
Handgrip smooth surface			
Handgrip diameter between 1½" and 2"			
Clearance of 1½" between wall and wall rail			
Non-slip surface			
Level platforms (4ft x 4 ft) at every 30 ft, at top, at bottom, at change of direction			

LOCATION

SITE ACCESS, PATH OF TRAVEL, ENTRANCES			
Specification	Yes	No	Comments/Transition Notes
Site Access			
Accessible path of travel from passenger disembarking area and parking area to accessible entrance			
Disembarking area at accessible entrance			
Surface evenly paved or hard-packed			
No ponding of water			
Path of Travel			
Path does not require the use of stairs			
Path is stable, firm and slip resistant			
3 ft wide minimum			
Slope maximum 1:20 (5%) and maximum cross pitch is 2% (1:50).			
Continuous common surface, no changes in level greater than 1/4 inch			
Any objects protruding onto the pathway must be detected by a person with a visual disability using a cane			
Objects protruding more than 4" from the wall must be within 27" of the ground, or higher than 80"			
Curb on the pathway must have curb cuts at drives, parking and drop-offs			
Entrances			
Primary public entrances accessible to person using wheelchair, must be signed, gotten to independently, and <i>not</i> be the service entrance			
Level space extending 5 ft. from the door, interior and exterior of entrance doors			
Minimum 32" clear width opening (i.e. 36" door with standard hinge)			
At least 18" clear floor area on latch, pull side of door			
Door handle no higher than 48" and operable with a closed fist			
Vestibule is 4 ft plus the width of the door swinging into the space			
Entrance(s) on a level that makes elevators accessible			
Door mats less than 1/2" thick are securely fastened			
Door mats more than 1/2" thick are recessed			
Grates in path of travel have openings of 1/2" maximum			
Signs at non-accessible entrance(s) indicate direction to accessible entrance			
Emergency egress - alarms with flashing lights and audible signals, sufficiently lighted			

NOTES THERE ARE 3 OR 4 SOCCER FIELDS DEPENDING HOW MANY GAMES ARE SET. PEOPLE CAN BRING CHAIRS (LIMITED) & WHEELCHAIRS CAN BE/CAN GO BUT THERE IS NO ACCESSIBLE PATH. MUST BE PUSHED/WHEELED OVER GRASS.

LOCATION

STAIRS and DOORS

NONE

Specification	Yes	No	Comments/Transition Notes
Stairs			
No open risers			
Nosings not projecting			
Treads no less than 11" wide			
Handrails on both sides			
Handrails 34"-38" above tread			
Handrail extends a minimum of 1 ft beyond top and bottom riser (if no safety hazard and space permits)			
Handgrip oval or round			
Handgrip has a smooth surface			
Handgrip diameter between 1½" and 1¾"			
1½" clearance between wall and handrail			
Doors			
Minimum 32" clear opening			
At least 18" clear floor space on pull side of door			
Closing speed minimum 3 seconds to within 3" of the latch			
Maximum pressure 5 pounds interior doors			
Threshold maximum ½" high, beveled on both sides			
Hardware operable with a closed fist (no conventional door knobs or thumb latch devices)			
Hardware minimum 36", maximum 48" above the floor			
Clear, level floor space extends out 5 ft from both sides of the door			
Door adjacent to revolving door is accessible and unlocked			
Doors opening into hazardous area have hardware that is knurled or roughened			

NOTES

LOCATION

SEE NOTES

RESTROOMS - also see Doors and Vestibules			
Specification	Yes	No	Comments/Transition Notes
5 ft turning space measured 12" from the floor			
<i>At least one Sink:</i>			
Clear floor space of 30" by 48" to allow a forward approach			
Mounted without pedestal or legs, height 34" to top of rim			
Extends at least 22" from the wall			
Open knee space a minimum 19" deep, 30" width, and 27" high			
Cover exposed pipes with insulation			
Faucets operable with closed fist (lever or spring activated handle)			
<i>At least one Stall:</i>			
Accessible to person using wheelchair at 60" wide by 72" deep			
Stall door is 36" wide			
Stall door swings out			
Stall door is self closing			
Stall door has a pull latch			
Lock on stall door is operable with a closed fist, and 32" above the floor			
Coat hook is 54" high			
<i>Toilet</i>			
18" from center to nearest side wall			
42" minimum clear space from center to farthest wall or fixture			
Top of seat 17"-19" above the floor			
<i>Grab Bars</i>			
On back and side wall closest to toilet			
1½" diameter			
1½" clearance to wall			
Located 30" above and parallel to the floor			
Acid-etched or roughened surface			
42" long			
<i>Fixtures</i>			
Toilet paper dispenser is 24" above floor			
One mirror set a maximum 38" to bottom (if tilted, 42")			
Dispensers (towel, soap, etc) at least one of each a maximum 42" above the floor			

NOTES THERE ARE MEN & WOMEN TOILETS. HANDICAPPED ACCESSIBLE TO - BUT TOILETS & SINKS DO NOT MEET FEDERAL GUIDELINES. REGULAR SIZE TOILETS/SINKS - NO GRAB BARS.

LOCATION

FLOORS, DRINKING FOUNTAINS, TELEPHONES			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/Transition Notes</i>
Floors			
Non-slip surface		✓	
Carpeting is high-density, low pile, non-absorbent, stretched taut, securely anchored			
Corridor width minimum is 3 ft			
Objects (signs, ceiling lights, fixtures) can only protrude 4" into the path of travel from a height of 27" to 80" above the floor			
Drinking Fountains <i>NONE</i>			
Spouts no higher than 36" from floor to outlet			
Hand operated push button or level controls			
Spouts located near front with stream of water as parallel to front as possible			
If recessed, recess a minimum 30" width, and no deeper than depth of fountain			
If no clear knee space underneath, clear floor space 30" x 48" to allow parallel approach			
Telephones <i>NONE</i>			
Highest operating part a maximum 54" above the floor			
Access within 12" of phone, 30" high by 30" wide			
Adjustable volume control on headset so identified			
SIGNS, SIGNALS, AND SWITCHES <i>NONE</i>			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/Transition Notes</i>
Switches, Controls and Signs			
Switches and controls for light, heat, ventilation, windows, fire alarms, thermostats, etc, must be a minimum of 36" and a maximum of 48" above the floor for a forward reach, a maximum of 54" for a side reach			
Electrical outlets centered no lower than 18" above the floor			
Warning signals must be visual as well as audible			
Signs			
Mounting height must be 60" to centerline of the sign			
Within 18" of door jamb or recessed			
Letters and numbers at least 1½" high			
Letters and numbers raised .03"			
Letters and numbers contrast with the background color			

NOTES

Facility Inventory

LOCATION: *TENNIS COURTS - MEMORIAL DR.*

ACTIVITY	EQUIPMENT	NOTES
Picnic Facilities	Tables & Benches	Located adjacent to accessible paths
		Access to Open Spaces
	Grills	Back and Arm Rests
		Adequate number
		Height of Cooking Surface
Trash Cans	Located adjacent to accessible paths	
	Located adjacent to accessible paths	
Picnic Shelters	Located adjacent to accessible paths	
	Located near accessible water fountains, trash can, restroom, parking, etc.	
Trails		Surface material
		Dimensions
		Rails
		Signage (for visually impaired)
Swimming Facilities	Pools	Entrance
		Location from accessible parking
		Safety features i.e. warning for visually impaired
	Beaches	Location from accessible path into water
		Handrails
		Location from accessible parking
Play Areas (tot lots)	All Play Equipment i.e. swings, slides	Same experience provided to all
		Access Routes
		Located adjacent to accessible paths
Game Areas: *ballfield *basketball <u>*tennis</u>	Access Routes	Enough space between equipment for wheelchair
		Located adjacent to accessible paths
	Equipment	Berm cuts onto courts
		Height
		Dimensions
	Spectator Seating <i>NO</i>	
Boat Docks	Access Routes	Located adjacent to accessible paths
		Handrails
Fishing Facilities	Access Routes	Located adjacent to accessible paths
		Handrails
	Equipment	Arm Rests
		Bait Shelves
		Handrails
	Fish Cleaning Tables	
Programming	Are special programs at your facilities accessible?	Learn-to-Swim
		Guided Hikes
		Interpretive Programs
Services and Technical Assistance	Information available in alternative formats i.e. for visually impaired	
		Process to request interpretive services (i.e. sign language interpreter) for meetings

LOCATION

PARKING		NONE	
Total Spaces	Required Accessible Spaces		
Up to 25	1 space		
26-50	2 spaces		
51-75	3 spaces		
76-100	4 spaces		
101-150	5 spaces		
151-200	6 spaces		
201-300	7 spaces		
301-400	8 spaces		
401-500	9 spaces		
Specification for Accessible Spaces	Yes	No	Comments/Transition Notes
Accessible space located closest to accessible entrance		X	COURTS IN DISREPAIR
Where spaces cannot be located within 200 ft of accessible entrance, drop-off area is provided within 100 ft.			GRAVEL SURFACE -
Minimum width of 13 ft includes 8 ft space plus 5 ft access aisle			SLOPE TO ENTER MUCH MORE THAN 5%
Van space - minimum of 1 van space for every accessible space, 8 ft wide plus 8 ft aisle. Alternative is to make all accessible spaces 11 ft wide with 5 ft aisle.			SEE NOTES SUCCEEDING PAGES
Sign with international symbol of accessibility at each space or pair of spaces			
Sign minimum 5 ft, maximum 8 ft to top of sign		X	
Surface evenly paved or hard-packed (no cracks)		X	
Surface slope less than 1:20, 5%		X	
Curbside to pathway from parking lot at each space or pair of spaces, if sidewalk (curb) is present		X	
Curbside is a minimum width of 3 ft, excluding sloped sides, has sloped sides, all slopes not to exceed 1:12, and textured or painted yellow			
RAMPS			
Specification	Yes	No	Comments/Transition Notes
Slope Maximum 1:12			
Minimum width 4 ft between handrails			
Handrails on both sides if ramp is longer than 6 ft			
Handrails at 34" and 19" from ramp surface			
Handrails extend 12" beyond top and bottom			
Handgrip oval or round			
Handgrip smooth surface			
Handgrip diameter between 1 1/4" and 2"			
Clearance of 1 1/2" between wall and wall rail			
Non-slip surface			
Level platforms (4ft x 4 ft) at every 30 ft, at top, at bottom, at change of direction			

LOCATION

SITE ACCESS, PATH OF TRAVEL, ENTRANCES			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/Transition Notes</i>
Site Access			
Accessible path of travel from passenger disembarking area and parking area to accessible entrance			
Disembarking area at accessible entrance			
Surface evenly paved or hard-packed			
No ponding of water			
Path of Travel			
Path does not require the use of stairs			
Path is stable, firm and slip resistant		/	
3 ft wide minimum			
Slope maximum 1:20 (5%) and maximum cross pitch is 2% (1:50).		/	
Continuous common surface, no changes in level greater than 1/2 inch		/	
Any objects protruding onto the pathway must be detected by a person with a visual disability using a cane			
Objects protruding more than 4" from the wall must be within 27" of the ground, or higher than 80"			
Curb on the pathway must have curb cuts at drives, parking and drop-offs			
Entrances			
Primary public entrances accessible to person using wheelchair, must be signed, gotten to independently, and <i>not</i> be the service entrance			
Level space extending 5 ft. from the door, interior and exterior of entrance doors			
Minimum 32" clear width opening (i.e. 36" door with standard hinge)			
At least 18" clear floor area on latch, pull side of door			
Door handle no higher than 48" and operable with a closed fist			
Vestibule is 4 ft plus the width of the door swinging into the space			
Entrance(s) on a level that makes elevators accessible			
Door mats less than 1/2" thick are securely fastened			
Door mats more than 1/2" thick are recessed			
Grates in path of travel have openings of 1/2" maximum			
Signs at non-accessible entrance(s) indicate direction to accessible entrance			
Emergency egress - alarms with flashing lights and audible signals, sufficiently lighted			

NOTES NO ASPHALT FOR PARKING AREA - ROCK GRAVEL ABOUT 40% GRADE - NO SIGNAGE

LOCATION

STAIRS and DOORS			
Specification	Yes	No	Comments/Transition Notes
<i>Stairs</i>			
No open risers			
Nosings not projecting			
Treads no less than 11" wide			
Handrails on both sides			
Handrails 34"-38" above tread			
Handrail extends a minimum of 1 ft beyond top and bottom riser (if no safety hazard and space permits)			
Handgrip oval or round			
Handgrip has a smooth surface			
Handgrip diameter between 1½" and 1¾"			
1½" clearance between wall and handrail			
<i>Doors</i>			
Minimum 32" clear opening			
At least 18" clear floor space on pull side of door			
Closing speed minimum 3 seconds to within 3" of the latch			
Maximum pressure 5 pounds interior doors			
Threshold maximum ½" high, beveled on both sides			
Hardware operable with a closed fist (no conventional door knobs or thumb latch devices)			
Hardware minimum 36", maximum 48" above the floor			
Clear, level floor space extends out 5 ft from both sides of the door			
Door adjacent to revolving door is accessible and unlocked			
Doors opening into hazardous area have hardware that is knurled or roughened			

NOTES

LOCATION

RESTROOMS - also see Doors and Vestibules			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/Transition Notes</i>
5 ft turning space measured 12" from the floor			
<i>At least one Sink:</i>			
Clear floor space of 30" by 48" to allow a forward approach			
Mounted without pedestal or legs, height 34" to top of rim			
Extends at least 22" from the wall			
Open knee space a minimum 19" deep, 30" width, and 27" high			
Cover exposed pipes with insulation			
Faucets operable with closed fist (lever or spring activated handle)			
<i>At least one Stall:</i>			
Accessible to person using wheelchair at 60" wide by 72" deep			
Stall door is 36" wide			
Stall door swings out			
Stall door is self closing			
Stall door has a pull latch			
Lock on stall door is operable with a closed fist, and 32" above the floor			
Coat hook is 54" high			
<i>Toilet</i>	<i>NONE</i>		
18" from center to nearest side wall			
42" minimum clear space from center to farthest wall or fixture			
Top of seat 17"-19" above the floor			
<i>Grab Bars</i>			
On back and side wall closest to toilet			
1½" diameter			
1½" clearance to wall			
Located 30" above and parallel to the floor			
Acid-etched or roughened surface			
42" long			
<i>Fixtures</i>			
Toilet paper dispenser is 24" above floor			
One mirror set a maximum 38" to bottom (if tilted, 42")			
Dispensers (towel, soap, etc) at least one of each a maximum 42" above the floor			

NOTES

LOCATION

FLOORS, DRINKING FOUNTAINS, TELEPHONES

<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/Transition Notes</i>
Floors			
Non-slip surface			
Carpeting is high-density, low pile, non-absorbent, stretched taut, securely anchored			
Corridor width minimum is 3 ft			
Objects (signs, ceiling lights, fixtures) can only protrude 4" into the path of travel from a height of 27" to 80" above the floor			
Drinking Fountains			
Spouts no higher than 36" from floor to outlet			
Hand operated push button or level controls			
Spouts located near front with stream of water as parallel to front as possible			
If recessed, recess a minimum 30" width, and no deeper than depth of fountain			
If no clear knee space underneath, clear floor space 30" x 48" to allow parallel approach			
Telephones			
Highest operating part a maximum 54" above the floor			
Access within 12" of phone, 30" high by 30" wide			
Adjustable volume control on headset so identified			
SIGNS, SIGNALS, AND SWITCHES			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/Transition Notes</i>
Switches, Controls and Signs			
Switches and controls for light, heat, ventilation, windows, fire alarms, thermostats, etc, must be a minimum of 36" and a maximum of 48" above the floor for a forward reach, a maximum of 54" for a side reach			
Electrical outlets centered no lower than 18" above the floor			
Warning signals must be visual as well as audible			
Signs			
Mounting height must be 60" to centerline of the sign			
Within 18" of door jamb or recessed			
Letters and numbers a t least 1½" high			
Letters and numbers raised .03"			
Letters and numbers contrast with the background color			

NOTES

Facility Inventory

LOCATION: *MEMORIAL BEACH*

ACTIVITY	EQUIPMENT	NOTES
Picnic Facilities	Tables & Benches	Located adjacent to accessible paths
		Access to Open Spaces
		Back and Arm Rests
		Adequate number
	Grills	Height of Cooking Surface Located adjacent to accessible paths
Trash Cans		Located adjacent to accessible paths
	Picnic Shelters <i>NONE</i>	Located adjacent to accessible paths Located near accessible water fountains, trash can, restroom, parking, etc.
Trails	<i>NONE</i>	Surface material
		Dimensions
		Rails
		Signage (for visually impaired)
Swimming Facilities	Pools <i>NONE</i>	Entrance
		Location from accessible parking
		Safety features i.e. warning for visually impaired
	Beaches	Location from accessible path into water <i>NO</i>
		Handrails <i>NO</i> Location from accessible parking ✓ Shade provided ✓
Play Areas (tot lots)	All Play Equipment i.e. swings, slides	Same experience provided to all <i>NO</i>
	Access Routes	Located adjacent to accessible paths <i>NO</i> Enough space between equipment for wheelchair <i>NO</i>
Game Areas: *ballfield <u>*basketball</u> *tennis	Access Routes	Located adjacent to accessible paths ✓ Berm cuts onto courts ✓
	Equipment	Height <i>10'</i>
		Dimensions <i>30x50</i>
Spectator Seating ✓		
Boat Docks	Access Routes	Located adjacent to accessible paths <i>NO</i>
		Handrails <i>NO</i>
Fishing Facilities	Access Routes	Located adjacent to accessible paths <i>NO</i>
		Handrails <i>NO</i>
	Equipment	Arm Rests <i>NO</i>
		Bait Shelves <i>NO</i>
		Handrails <i>NO</i> Fish Cleaning Tables <i>NO</i>
<i>NO</i> Programming	Are special programs at your facilities accessible?	Learn-to-Swim <i>NO</i>
		Guided Hikes <i>NO</i>
		Interpretive Programs <i>NO</i>
Services and Technical Assistance	Information available in alternative formats i.e. for visually impaired	
	Process to request interpretive services (i.e. sign language interpreter) for meetings	

LOCATION

PARKING			
<i>Total Spaces</i>	<i>Required Accessible Spaces</i>		
Up to 25	1 space		
26-50	2 spaces		
51-75	3 spaces		
76-100	4 spaces		
101-150	5 spaces		
151-200	6 spaces ✓		
201-300	7 spaces		
301-400	8 spaces		
401-500	9 spaces		
<i>Specification for Accessible Spaces</i>	<i>Yes</i>	<i>No</i>	<i>Comments/Transition Notes</i>
Accessible space located closest to accessible entrance	✓		
Where spaces cannot be located within 200 ft of accessible entrance, drop-off area is provided within 100 ft.	✓		
Minimum width of 13 ft includes 8 ft space plus 5 ft access aisle			
Van space - minimum of 1 van space for every accessible space, 8 ft wide plus 8 ft aisle. Alternative is to make all accessible spaces 11 ft wide with 5 ft aisle.		✓	
Sign with international symbol of accessibility at each space or pair of spaces	✓		
Sign minimum 5 ft, maximum 8 ft to top of sign	✓		
Surface evenly paved or hard-packed (no cracks)	✓		
Surface slope less than 1:20, 5%	✓		
Curbscut to pathway from parking lot at each space or pair of spaces, if sidewalk (curb) is present	✓		
Curbscut is a minimum width of 3 ft, excluding sloped sides, has sloped sides, all slopes not to exceed 1:12, and textured or painted yellow	-		NO CURB CUT NEEDED
RAMPS NO RAMPS NEEDED			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/Transition Notes</i>
Slope Maximum 1:12		1	
Minimum width 4 ft between handrails			
Handrails on both sides if ramp is longer than 6 ft			
Handrails at 34" and 19" from ramp surface			
Handrails extend 12" beyond top and bottom			
Handgrip oval or round			
Handgrip smooth surface			
Handgrip diameter between 1½" and 2"			
Clearance of 1½" between wall and wall rail			
Non-slip surface			
Level platforms (4ft x 4 ft) at every 30 ft, at top, at bottom, at change of direction			

LOCATION

SITE ACCESS, PATH OF TRAVEL, ENTRANCES			
Specification	Yes	No	Comments/Transition Notes
Site Access			
Accessible path of travel from passenger disembarking area and parking area to accessible entrance	✓		
Disembarking area at accessible entrance	✓		
Surface evenly paved or hard-packed	✓		
No ponding of water	✓		
Path of Travel			
Path does not require the use of stairs	✓		NO STAIRS NEEDED
Path is stable, firm and slip resistant	✓		
3 ft wide minimum	✓		
Slope maximum 1:20 (5%) and maximum cross pitch is 2% (1:50).	✓		
Continuous common surface, no changes in level greater than 1/2 inch	✓		
Any objects protruding onto the pathway must be detected by a person with a visual disability using a cane		✓	
Objects protruding more than 4" from the wall must be within 27" of the ground, or higher than 80"		✓	
Curb on the pathway must have curb cuts at drives, parking and drop-offs		✓	
Entrances			
Primary public entrances accessible to person using wheelchair, must be signed, gotten to independently, and <i>not</i> be the service entrance			NO SIGNS
Level space extending 5 ft. from the door, interior and exterior of entrance doors	✓		
Minimum 32" clear width opening (i.e. 36" door with standard hinge)	✓		
At least 18" clear floor area on latch, pull side of door	✓		
Door handle no higher than 48" and operable with a closed fist	✓		
Vestibule is 4 ft plus the width of the door swinging into the space	✓		
Entrance(s) on a level that makes elevators accessible			NO ELEVATORS NEEDED
Door mats less than 1/2" thick are securely fastened			NOT NEEDED
Door mats more than 1/2" thick are recessed			NO GRATES
Grates in path of travel have openings of 1/2" maximum			
Signs at non-accessible entrance(s) indicate direction to accessible entrance			NO SIGNS NEEDED
Emergency egress - alarms with flashing lights and audible signals, sufficiently lighted	✓		

NOTES

LOCATION

STAIRS and DOORS			
Specification	Yes	No	Comments/Transition Notes
<i>Stairs</i> NO STAIRS			
No open risers			
Nosings not projecting			
Treads no less than 11" wide			
Handrails on both sides			
Handrails 34"-38" above tread			
Handrail extends a minimum of 1 ft beyond top and bottom riser (if no safety hazard and space permits)			
Handgrip oval or round			
Handgrip has a smooth surface			
Handgrip diameter between 1¼" and 1½"			
1½" clearance between wall and handrail			
<i>Doors</i>			
Minimum 32" clear opening	✓		
At least 18" clear floor space on pull side of door	✓		
Closing speed minimum 3 seconds to within 3" of the latch	✓		
Maximum pressure 5 pounds interior doors	✓		
Threshold maximum ½" high, beveled on both sides	✓		
Hardware operable with a closed fist (no conventional door knobs or thumb latch devices)		✓	
Hardware minimum 36", maximum 48" above the floor	✓		
Clear, level floor space extends out 5 ft from both sides of the door	✓		
Door adjacent to revolving door is accessible and unlocked			NO REVOLVING DOOR
Doors opening into hazardous area have hardware that is knurled or roughened			NO HAZARDOUS AREA

NOTES

LOCATION

RESTROOMS - also see Doors and Vestibules			
<i>Specification</i>	<i>Yes</i>	<i>No</i>	<i>Comments/Transition Notes</i>
5 ft turning space measured 12" from the floor	✓		
At least one Sink:			
Clear floor space of 30" by 48" to allow a forward approach	✓		
Mounted without pedestal or legs, height 34" to top of rim	✓		
Extends at least 22" from the wall	✓		
Open knee space a minimum 19" deep, 30" width, and 27" high	✓		
Cover exposed pipes with insulation			NONE EXPOSED
Faucets operable with closed fist (lever or spring activated handle)	✓		
At least one Stall:			
Accessible to person using wheelchair at 60" wide by 72" deep	✓		
Stall door is 36" wide	✓		
Stall door swings out		✓	
Stall door is self closing		✓	
Stall door has a pull latch	✓		
Lock on stall door is operable with a closed fist, and 32" above the floor	✓		
Coat hook is 54" high		✓	
Toilet			
18" from center to nearest side wall	✓		
42" minimum clear space from center to farthest wall or fixture	✓		
Top of seat 17"-19" above the floor	✓		
Grab Bars			
On back and side wall closest to toilet	✓		
1½" diameter	✓		
1½" clearance to wall	✓		
Located 30" above and parallel to the floor	✓		
Acid-etched or roughened surface	✓		
42" long	✓		
Fixtures			
Toilet paper dispenser is 24" above floor	✓		
One mirror set a maximum 38" to bottom (if tilted, 42")	✓		
Dispensers (towel, soap, etc) at least one of each a maximum 42" above the floor	✓		

NOTES

LOCATION

FLOORS, DRINKING FOUNTAINS, TELEPHONES			
Specification	Yes	No	Comments/Transition Notes
<i>Floors</i>			
Non-slip surface		✓	
Carpeting is high-density, low pile, non-absorbent, stretched taut, securely anchored		✓	
Corridor width minimum is 3 ft	✓		
Objects (signs, ceiling lights, fixtures) can only protrude 4" into the path of travel from a height of 27" to 80" above the floor		✓	
<i>Drinking Fountains</i>			
Spouts no higher than 36" from floor to outlet	✓		
Hand operated push button or level controls	✓		
Spouts located near front with stream of water as parallel to front as possible	✓		
If recessed, recess a minimum 30" width, and no deeper than depth of fountain			NOT RECESSED
If no clear knee space underneath, clear floor space 30" x 48" to allow parallel approach	✓		
<i>Telephones</i>			
Highest operating part a maximum 54" above the floor			NO PHONES
Access within 12" of phone, 30" high by 30" wide			
Adjustable volume control on headset so identified			
<i>SIGNS, SIGNALS, AND SWITCHES</i>			
Specification	Yes	No	Comments/Transition Notes
<i>Switches, Controls and Signs</i>			
Switches and controls for light, heat, ventilation, windows, fire alarms, thermostats, etc, must be a minimum of 36" and a maximum of 48" above the floor for a forward reach, a maximum of 54" for a side reach			LIGHTS OPERATED BY PARKS DEPT
Electrical outlets centered no lower than 18" above the floor	✓		
Warning signals must be visual as well as audible			
<i>Signs</i>			
Mounting height must be 60" to centerline of the sign		✓	
Within 18" of door jamb or recessed	✓		
Letters and numbers at least 1½" high	✓		
Letters and numbers raised .03"		✓	
Letters and numbers contrast with the background color	✓		

NOTES